

LABORATORY SERVICES REPORT

Terracon

Report Number: N1171191.0001
Service Date: 11/22/17
Report Date: 11/27/17

611 Lunken Park Dr
Cincinnati, OH 45226-1813
513-321-5816

Client

Chemtec International, Inc.
Attn: James Sist
7771 Woodstone Drive Ste 100
Cincinnati, OH 45244

Project

Chemtec One Testing
611 Lunken Park Dr.
Cincinnati, OH 45226

Project Number: N1171191

Table III
Standard Test Method for Density, Absorption, and Voids in Hardened Concrete
(ASTM C642-06)

Sample	Absorption Result after 48 hours	Absorption after 50 days
ChemTec ONE Treated 1	0.18%	0.49%

The ChemTec ONE treated sample results above were previously reported in Terracon report No. N1091141.0001 for ChemTec International.

Services:

Terracon Rep.: Stransky, Terry


Reported To:

Contractor:

Report Distribution:

(1) Chemtec International, Inc., James Sist

Reviewed By:


Jason A. Sander, P.E.
Office Manager

The tests were performed in general accordance with applicable ASTM, AASHTO, or DOT test methods. This report is exclusively for the use of the client indicated above and shall not be reproduced except in full without the written consent of our company. Test results transmitted herein are only applicable to the actual samples tested at the location(s) referenced and are not necessarily indicative of the properties of other apparently similar or identical materials.